

PAPER • OPEN ACCESS

# A facility for radiation hardness studies based on a medical cyclotron

To cite this article: J. Anders *et al* 2022 *JINST* 17 P04021

View the [article online](#) for updates and enhancements.

You may also like

- [Study of radiation hardness of Gd<sub>2</sub>SiO<sub>5</sub> scintillator for heavy ion beam](#)  
K Kawade, K Fukatsu, Y Itow et al.
- [Ultrasound device selection by using F-ANP and COPRAS](#)  
Humala L Napitupulu
- [A review of printable, flexible and tissue equivalent materials for ionizing radiation detection](#)  
Jessie A Posar, Marco Petasecca and Matthew J Griffith

## A facility for radiation hardness studies based on a medical cyclotron

J. Anders, S. Braccini, T.S. Carzaniga,<sup>1</sup> P. Casolaro, M. Chatterjee, G. Dellepiane, L. Franconi, L. Halser, A. Ilg,<sup>2</sup> I. Mateu,\* F. Meloni,<sup>3</sup> C. Merlassino,<sup>4</sup> A. Miucci,<sup>5</sup> R. Müller, M. Rimoldi<sup>3</sup> and M. Weber

*Albert Einstein Center for Fundamental Physics (AEC), Laboratory for High Energy Physics (LHEP), Sidlerstrasse 5, CH-3012 Bern, Switzerland*

*E-mail: [isidro.mateu@lhep.unibe.ch](mailto:isidro.mateu@lhep.unibe.ch)*

**ABSTRACT:** The development of instrumentation for operation in high-radiation environments represents a challenge in various research fields, particularly in particle physics experiments and space missions, and drives an ever-increasing demand for irradiation facilities dedicated to radiation hardness studies. Depending on the application, different needs arise in terms of particle type, energy and dose rate. In this article, we present a versatile installation based on a medical cyclotron located at the Bern University Hospital (Inselspital), which is used as a controlled 18-MeV proton source. This accelerator is used for daily production of medical radioisotopes, as well as for multidisciplinary research, thanks to a 6.5-meter long beam transfer line that terminates in an independent bunker, dedicated only to scientific activities. The facility offers a wide range of proton fluxes, due to an adjustable beam current from approximately 10 pA to the micro-ampere range, together with a series of steering and focusing magnets along the beamline that allow for the beam spot to be focused down to a few mm<sup>2</sup>. The beamline can be instrumented with a variety of beam monitoring detectors, collimators, and beam current measurement devices to precisely control the irradiation conditions. The facility also hosts a well equipped laboratory dedicated to the characterisation of samples after irradiation. An experimental validation of the irradiation setup, with proton fluxes ranging from  $5 \times 10^9 \text{ cm}^{-2}\text{s}^{-1}$  to  $4 \times 10^{11} \text{ cm}^{-2}\text{s}^{-1}$ , is reported.

**KEYWORDS:** Accelerator Applications; Beam-line instrumentation (beam position and profile monitors, beam-intensity monitors, bunch length monitors); Radiation damage to detector materials (solid state); Radiation damage to electronic components

**ARXIV EPRINT:** [2201.04176](https://arxiv.org/abs/2201.04176)

<sup>1</sup>Now at SWAN Isotopen AG, Bern, Switzerland.

<sup>2</sup>Now at University of Zurich, Zurich, Switzerland.

<sup>3</sup>Now at Deutsches Elektronen-Synchrotron DESY, Hamburg, Germany.

<sup>4</sup>Now at University of Oxford, Oxford, U.K.

<sup>5</sup>Now at Helbling Technik AG, Wil, Switzerland.

\*Corresponding author.



---

## Contents

<b>1</b>	<b>Introduction</b>	<b>1</b>
<b>2</b>	<b>The Bern medical cyclotron and beam transfer line</b>	<b>2</b>
<b>3</b>	<b>The irradiation facility</b>	<b>4</b>
3.1	Collimation and beam intensity measurement	5
3.2	Beam profile monitoring	5
3.3	Beam delivery and proton flux measurement	8
3.4	Validation of the irradiation setup	10
3.4.1	Validation using a Faraday Cup	10
3.4.2	Validation using radiochromic films	12
3.5	On site characterisation of the irradiated samples	13
<b>4</b>	<b>Examples of irradiation campaigns</b>	<b>13</b>
<b>5</b>	<b>Conclusions</b>	<b>15</b>

---

## 1 Introduction

Radiation Hardness Assurance (RHA) is a key aspect of scientific experiments carried out in high-radiation environments, where the replacement of defective equipment is not realistic from the point of view of cost, time, or access to the experimental area. Clear examples of such circumstances are space missions, in which systems must be designed to withstand the radiation levels expected during the whole mission's lifetime. To this end, ESA, NASA, and other space agencies carry out extensive R&D efforts for RHA and define strict protocols for the selection and testing of materials and components for their missions [1–3]. Similarly, the detector and accelerator components at the CERN Large Hadron Collider (LHC) [4] must operate at extraordinary levels of radiation for several years before being replaced according to a detailed plan of maintenance and upgrades. Specifically, the High-Luminosity upgrade of the LHC [5], with the aim of increasing the integrated luminosity by a factor of five by 2030, poses a challenge in terms of RHA for the sensor technologies and electronics [6–8]. Medical [9, 10] and nuclear [11, 12] applications are examples of other fields where RHA is of concern.

Three different mechanisms are responsible for radiation-induced damage to sensors and electronics: changes in digital electronics' logic states due to the interaction of a single ionising particle, commonly referred as single event effects, ionisation and trapping of charge in dielectrics such as the gate oxides present in integrated circuits, and dislocation of lattice atoms in semiconductors, also known as displacement damage (DD). While single event effects can occur at any time with a certain probability that depends on the particle flux, type and energy, charge trapping and DD are

cumulative effects, i.e. their severity depends on the cumulated radiation exposure of the device. Two quantities are used to measure them: Total Ionising Dose (TID) and 1-MeV neutron equivalent particle fluence<sup>1</sup> ( $n_{\text{eq}}/\text{cm}^2$ ). TID quantifies the amount of energy transferred to the material in the form of ionisation, eventually leading to charge trapping in insulating interfaces, and is expressed as energy per unit of mass. The SI unit is the Gray (Gy), where  $1 \text{ Gy} = 1 \text{ J/kg}$ . The 1-MeV neutron equivalent particle fluence quantifies DD, and is interpreted as the fluence of 1-MeV neutrons that would result in the same amount of DD as the real fluence delivered by an irradiation source of a given particle type and energy. The conversion factor (commonly known as hardness factor) to 1-MeV neutron equivalent fluence is given by the particle's Non-Ionising Energy Loss (NIEL) cross section. NIEL is defined as the amount of energy transferred to the material which does not result in ionisation, thus available for DD. Calculated values of NIEL cross sections in silicon for various particles can be found in [7].


The availability of dedicated irradiation facilities capable of delivering controlled fluence and TID levels plays a crucial role in qualifying the radiation hardness of components. Such facilities are rare and in high demand, so access to them is often limited. Furthermore, the characterisation and analysis of samples after irradiation is normally carried out in specialised laboratories, away from the irradiation facility. This often requires the shipment of radioactive materials, which results in delays, additional costs and complications for the user. We present here a medical cyclotron facility located at the Bern University Hospital (Inselspital), featuring an 18-MeV proton beamline dedicated to RHA tests and multidisciplinary research activities. A convenient feature of this facility is the availability of a dedicated characterisation laboratory (Physics Laboratory) within the radiation controlled area, which allows for post-irradiation studies on the device under test (DUT) to be performed directly in place and shortly after the irradiation. In this way, not only the mentioned difficulties associated to the shipment of radioactive samples can be avoided, but also the scientific outcome can be improved by minimising any undesired thermal annealing on the irradiated samples. A layout of the full facility is presented in figure 1. RHA tests at the Bern medical cyclotron focus primarily on TID and DD effects, while the possibilities for SEE testing have not been investigated so far. 18-MeV protons release a high amount of energy in matter in the form of ionisation (e.g. the electronic stopping power in silicon is  $\sim 22 \text{ MeV}/(\text{g}/\text{cm}^2)$ <sup>2</sup> compared to  $\sim 2 \text{ MeV}/(\text{g}/\text{cm}^2)$  for a minimum ionising particle (MIP)), thus enabling radiation hardness tests at very high TID. On the other hand, the hardness factor for conversion to 1-MeV neutron equivalent fluence is approximately 1.4 [7]. Practical information for users interested in conducting irradiation experiments in the facility, as well as contact details, can be found on the University of Bern's Laboratory for High Energy Physics (LHEP) website [14].

## 2 The Bern medical cyclotron and beam transfer line

The Bern cyclotron is a commercial IBA Cyclone 18/18, accelerating  $\text{H}^+$  ions to a kinetic energy of 18 MeV with a maximum extracted current of  $150 \mu\text{A}$  [15, 16]. Proton extraction is achieved by stripping the electrons from the accelerated  $\text{H}^+$  ions by means of thin pyrolytic carbon foils. The cyclotron is used routinely overnight to produce radioisotopes (namely  $^{18}\text{F}$ ) for PET diagnostics, and

<sup>1</sup>Particle fluence, or fluence, is used as a synonym of cumulated (integrated) particle flux in this paper.

<sup>2</sup>Electronic stopping power calculated using SRIM [13].




**Figure 1.** Layout of the cyclotron facility at the Bern Inselspital. It features two separate bunkers (depicted with their doors open in the figure) hosting the cyclotron and the BTL. In addition, a multi-purpose laboratory (Physics Laboratory) is available for post-irradiation studies.

is thus free for other research activities during the day. The on-going research programs include the production and study of novel radioisotopes for medical applications [17, 18], the development of beam-monitoring devices [19, 20], radiation protection studies [21] and radiation hardness studies, which are the subject of this article.

To perform radiation hardness tests, the extracted beam is transported via a 6.5-m long beam transfer line (BTL) [15] into a separate bunker, referred to as the BTL bunker in this document, as depicted in figure 2. The accelerated protons encounter first an X-Y steering magnet system and are afterwards focused using two, horizontal and vertical, quadrupole doublets: the first located in the cyclotron bunker and the second in the BTL bunker. Two movable, water-cooled, beam viewers are present along the beam line, providing a destructive measurement of the beam current with a sensitivity of 100 nA. A transmission efficiency greater than 95% is typically achieved from the beam current measured on the stripper to the one measured on the second beam viewer. The BTL is terminated with a target gate valve to preserve the vacuum in the beam pipe during the mounting of scientific equipment.

A 1.8-m thick concrete wall separates the two bunkers and prevents the neutron flux generated during the production of medical radioisotopes from reaching the BTL bunker. Furthermore, a cylindrical neutron shutter is inserted in the beam pipe while the BTL is not in use. Thanks to this two-bunker structure, the dose rate in the BTL bunker during the production is kept below  $2 \mu\text{Sv h}^{-1}$ .




**Figure 2.** Scheme of the cyclotron and irradiation bunkers. The cyclotron bunker is separated by a 1.8-m thick concrete wall from the BTL bunker where the irradiation apparatus is located. This allows for easy access to the DUT shortly after irradiation, due to the low level of activity in the BTL bunker (below  $2 \mu\text{Sv h}^{-1}$ ).

To use the cyclotron for irradiation purposes, a dedicated beam characterisation was performed. In particular, the beam energy distribution was studied with several methods: using a multi-leaf Faraday cup [22], measuring the beam transmission through aluminum absorbers of different thicknesses [23] and measuring the deflection angle introduced by a dipole electromagnet [24]. Additionally, the cyclotron operation settings were tuned for low output current operation, down to the pA range [25]. The need for such a low beam current was originally driven by radiobiology applications, while beam currents of the order of hundreds of nanoamperes are more typical during radiation hardness tests. However, being able to deliver beams over a wide range of intensities is of interest for applications where not only the total dose, but also dose rate effects, are of concern. It is worth noting that medical cyclotrons for radioisotope production are conceived to operate at currents larger than  $10 \mu\text{A}$ , and that the standard equipment (such as the beam viewers) is designed for this intensity range. In order to precisely determine the fluence and dose delivered to the DUT, it is fundamental to measure the beam current and monitor the beam profile during the irradiation. In order to do so, several dedicated instruments, presented in the next section, were developed at LHEP. The entire irradiation setup has been validated for a proton flux ranging from  $5 \times 10^9 \text{ cm}^{-2}\text{s}^{-1}$  to  $4 \times 10^{11} \text{ cm}^{-2}\text{s}^{-1}$ .

### 3 The irradiation facility

The BTL ends in the BTL bunker, a  $5.4 \times 4.0 \text{ m}^2$  room dedicated to research activities. Approximately 3 meters from the end of the BTL to the bunker wall are available for the irradiation setup. An



**Figure 3.** Irradiation setup. It consists of a quadrupole doublet (1), a beam viewer (2), the target vacuum valve (3), the two-dimensional beam profile monitor  $\pi^2$  (4) and the collimator terminated with an aluminium extraction window (5). The DUT is mounted and aligned on the remote controllable 2D stage (6).


irradiation table, an X-Y motorised stage system, as well as multiple tripodes, supports, and lead bricks are available for the installation of the DUT. Furthermore, the room is equipped with 220 V power sockets, Ethernet, fibre optic, BNC and SHV connections to the Physics Laboratory, enabling the active readout of the device during irradiation. Temperature control on the DUT is also possible with Peltier elements and/or water cooling.

Irradiations are typically carried out in air (although irradiations in vacuum are also possible) using the configuration shown in figure 3. Right after the vacuum valve that terminates the BTL, a beam profile monitor is installed to measure the transverse beam profile, followed by a collimator that also acts as a beam current measuring device. The collimator aperture can be changed, depending on the desired beam spot size, with a maximum of  $30 \times 30 \text{ mm}^2$ . Real-time monitoring of the proton flux delivered to the DUT is achieved by combining the beam intensity and profile measurements. After the collimator, the beam is extracted in air through a  $300\text{-}\mu\text{m}$  thick aluminium window. The DUT is typically placed as close to the extraction window as possible, in order to minimise the distance travelled in air by the protons. As a radioprotection measure, the radioactivity in air is continuously monitored in the facility [21].

The DUT can be installed on the remotely controlled two-dimensional motorized stage system shown in figure 3. Multiple DUTs can be mounted on the stage system and irradiated consecutively without need to enter the BTL bunker. Stacking of multiple DUTs is rarely possible due to the beam's short radiation length in most materials. The stage system features a  $30 \times 30 \text{ cm}^2$  grid of M6 threaded holes spaced with a 2.5 cm pitch, and can hold up to 8 kg. Larger samples can be installed on other supports such as tripodes or tables, also available in the facility. A laser system for the horizontal and vertical alignment of the DUT with the centre of the beam pipe is installed in the bunker.

### 3.1 Collimation and beam intensity measurement

To measure the beam current, a dedicated collimator was developed. Its cross-section is shown in figure 4. It consists of three aluminium rings: the shaping ring, the bias ring, and the dump ring,




**Figure 4.** Cross-section of the current measuring collimator (left) and view of the instrument from the point of view of the DUT (right).

each of them 5-mm thick (18-MeV protons have a range of 1.6 mm in aluminium). The proton beam enters the collimator through a 40-mm diameter aperture and is first shaped by the shaping ring (35-mm diameter). Then, the dump ring stops the outer part of the beam, while the central part is collimated according to the chosen aperture (several versions of the dump ring are available, with aperture sizes from  $5 \times 5 \text{ mm}^2$  to  $30 \times 30 \text{ mm}^2$ ). The dump ring is electrically connected to an electrometer in order to measure the intercepted beam. A 100 V negative potential, applied to the biasing ring, prevents Secondary Electron Emission (SEE) from the dump ring, which would lead to an up to 20% current overestimation, as documented in [25]. The collimator is connected at the end of the BTL and is operated in vacuum to prevent electrons from ionised air molecules from being collected by the dump ring.

### 3.2 Beam profile monitoring

Two different devices, the so called UniBEaM [26] and  $\pi^2$  [19] detectors, were developed for monitoring the beam profile and position. Both are enclosed in vacuum-tight structures and can be easily installed in the beam line according to specific needs. Typically, the beam profile monitor is installed upstream from the collimator described in the previous section, in order to measure the beam footprint over the whole collimator's dump ring area.


The UniBEaM (figure 5, left) uses doped-silica optical fibres (200- $\mu\text{m}$  diameter) as scintillating elements. In order to determine the horizontal projection of the transverse profile, one such fibre, vertically oriented, is continuously moved along the horizontal axis by means of a stepper motor. The range of movement covers the full 3-cm diameter circular aperture of the instrument. Part of the scintillating light propagates in the fibre and is transmitted via a fibre optic cable to a photo-detector located outside the BTL bunker. Dedicated software controls the motor movement and retrieves the light intensity information to reconstruct and display the beam profile in real time. The vertical



**Figure 5.** The commercial version of the UniBEaM (left) [26] and the  $\pi^2$  (right) [19] beam profile monitors at the Bern cyclotron. Both devices are seen from the point of view of the DUT.

profile is measured in an analogous fashion by a second fibre, oriented horizontally and moved along the vertical axis. The motor speed is such that it takes only a few seconds for a fibre to scan its full range of motion. The fibre movement can be turned off after the initial tuning of the beam, to avoid any disturbance on the beam during irradiation. Figure 6 shows an example of the typical profile achieved with the BTL magnets configured for broad beam conditions. Under these conditions, the beam footprint is well described by a two-dimensional Gaussian probability density function (PDF). The horizontal and vertical projections of a fit to this PDF are also included in the figure. The laboratory is equipped with several UniBEaM detectors produced by LHEP and a commercial version by the canadian company D-PACE (under licence from the University of Bern) [27].

The  $\pi^2$  detector (figure 5, right) consists of a scintillating foil installed at the centre of a 4-way vacuum cross. The foil is a 15- $\mu\text{m}$  thick aluminium, coated with a cerium and terbium doped yttrium orthosilicate ( $\text{Y}_2\text{SiO}_5:\text{Ce},\text{Tb}$ ) Phosphor screen (P47 compound), and is placed at a  $45^\circ$  angle with respect to the beam axis. The beam footprint on the scintillator is imaged with an ISC-1781 camera from National Instruments, looking at the foil through an optical window installed on the upper port of the cross. The foil covers a 6-cm diameter circular area orthogonal to the beam axis, thus enabling the observation of the full beam profile in any configuration. An earlier version of the same detector, covering only a 4-cm diameter [19], is also available. An Ethernet connection from the camera to a PC in the control room allows the image to be retrieved and processed using commercial software from National Instruments. The software allows to apply a transformation matrix to the image in order to correct for the perspective effect due to the  $45^\circ$  orientation of the camera with respect to the foil. A dedicated calibration using millimeter paper instead of the scintillating foil was performed to




**Figure 6.** Beam profile at the end of the BTL, measured by the UniBEaM profile monitor.

obtain the appropriate transformation matrix. Figure 7, demonstrates the perspective effect in the raw image captured by the camera (left) and the applied correction (right). To obtain this image, the normal order of the beam profile monitor and collimator was inverted: the collimator, with a  $2.5 \times 2.5 \text{ cm}^2$  aperture, was installed upstream from the  $\pi^2$ .


Note that, because of its larger aperture, the  $\pi^2$  allows to monitor broader beams than the UniBEaM. (6 cm versus 4 cm diameter). Moreover, a greater sensitivity can be achieved with the  $\pi^2$  by increasing the camera exposure time. One drawback of this detector, however, is the potential non-uniform light yield of the scintillating foil either due to an irregular initial deposition of P47, or to a degradation after long term irradiation exposure. Corrections to this effect can be achieved by performing periodical calibrations against other beam profile measurements (e.g. the UniBEaM detector or radiochromic films).

### 3.3 Beam delivery and proton flux measurement

Downstream from the beam profile monitor and the collimator, the beam is extracted from vacuum to air and onto the DUT through a 300- $\mu\text{m}$  thick aluminium window. To study the effect on the beam energy, the energy PDF obtained in a previous measurement [23], and shown by the square points in figure 8, was considered. The PDF was fitted with a Verhulst function shown by the red curve. The stopping power of aluminium for protons, calculated with SRIM [13], was used to derive the energy PDF after the extraction window, represented by the blue circles in figure 8. A fit to a Verhulst function



**Figure 7.** Left: raw image of the beam footprint obtained with the  $\pi^2$  beam profiler. Right: same image, after post-processing to correct for perspective effects.



**Figure 8.** Distribution of the proton energy before and after extraction. The square points are the measured energy profile of the beam before extraction [23], fitted with a Verhulst function. The effect of a 300  $\mu\text{m}$  aluminium extraction window has been simulated and is shown by the circle markers.

convoluted with a Gaussian resulted in a mean energy of  $16.7 \pm 0.5$  MeV. For reference, table 1 shows the electronic and nuclear stopping power of different materials for a 16.7 MeV proton beam.

The measurement of the beam current during irradiation allows for the monitoring of the proton flux in real time, and is automatically recorded for offline analysis. In particular, the dose rate measurement is relevant to identify non-linear effects in electronics, as discussed in [29]. Assuming

**Table 1.** Electronic stopping power for different materials in case of a 16.7 MeV proton beam. The values are obtained from the NIST database [28].

Material	$\frac{1}{\rho} \frac{dE}{dx}_{\text{ion}} \left[ \text{MeV} \frac{\text{cm}^2}{\text{g}} \right]$	$\frac{1}{\rho} \frac{dE}{dx}_{\text{nuc}} \left[ \text{MeV} \frac{\text{cm}^2}{\text{g}} \right]$
Silicon	23.25	0.011
Silicon dioxide	24.31	0.012
Aluminium	22.67	0.011
Plastic scintillator (Vyniltoluene)	30.12	0.015
Mylar	28.06	0.013
Photographic emulsion	18.30	0.009

a uniform beam profile, the proton flux delivered to the DUT can be calculated from the beam current measured on the collimator as:

$$\phi(t) = \frac{j(t)}{Q_e} \quad (3.1)$$

where  $j(t)$  is the current per unit area, and  $Q_e$  is the elementary charge. Assuming an incoming beam with a uniform flux density,  $j(t)$  is calculated from the ratio between the current measured on the dump ring of the collimator system and its area. A close-to-uniform (within 20%) profile is achieved by switching off the last quadrupole doublet in the BTL line.


A better estimation of the flux can be obtained by taking into account the measured beam profile. In this case, the flux can be calculated as:

$$\phi(t) = \frac{\int_{A_{\text{DUT}}} P(x, y) dS}{\int_{A_{\text{coll}}} P(x, y) dS} \cdot \frac{A_{\text{coll}}}{A_{\text{DUT}}} \cdot \frac{j(t)}{Q_e} \quad (3.2)$$

where  $P(x, y)$  is the transverse beam profile measured by the beam monitor, and  $A_{\text{DUT}}$  and  $A_{\text{coll}}$  are the areas of the DUT and the collimator (which varies according to the selected aperture), respectively.

A dedicated simulation was performed to estimate the uncertainty associated to this flux calculation method, considering  $P(x, y)$  to be the 2D Gaussian fit of the UniBEaM measured profile with typical broad beam settings, shown in figure 6. The simulation considered the statistical fluctuations on the current measurements, the uncertainties on the beam profile fit parameters, and conservative estimates of 500  $\mu\text{m}$  (one sigma) for the tolerance on the dump ring diameter and aperture dimensions, and 1 mm (one sigma) for the tolerance on the alignment of the collimator, the UniBEaM and the DUT. The overall uncertainty determined by the simulation was of approximately 10%.

Figure 9 shows an example of the beam current intercepted by the dump ring and the proton fluence during a typical irradiation. The blue curve represents the fluence with the quoted 10% uncertainty. The beam intensity downward drift over time is due to the warm-up of the cyclotron main coil, which causes a variation of the magnetic field intensity and thus a loss of resonance with the electric field's alternating frequency. This effect is mitigated by the operator by periodically adjusting the main coil current. Ultimately, a beam current stability over time of approximately 10% can be easily achieved.



**Figure 9.** Observed beam current during an irradiation (red trace), together with the proton fluence delivered to the DUT (blue trace, the shaded area represents the 10% uncertainty on the fluence measurement). The steps in the beam current are due to the beam tuning performed by the cyclotron operator.

### 3.4 Validation of the irradiation setup


To validate the proton flux calculation method described in the previous section, two independent tests were carried out: the first using a Faraday cup, the second using calibrated radiochromic films.

#### 3.4.1 Validation using a Faraday Cup

In this experiment, a high-sensitivity Faraday cup was installed after the collimator to obtain a direct measurement of the beam current at the DUT position. A picture of the setup is shown in figure 10. The beam profile monitor was installed as first device at the end of the BTL (although only the UniBEaM is shown in the picture, the experiment was performed also with the  $\pi^2$  device), immediately followed by the collimator and the Faraday cup. Following the same working principle of the collimator, described in section 3.1, the Faraday cup is also equipped with a repelling electrode to counteract SEE. In this experiment, a common 100 V negative potential was applied to both repelling electrodes (collimator and Faraday cup). For both devices, the effect of the biasing voltage saturates above 50 V.

Equation 3.2 was used to calculate the proton flux on the DUT. In the case of the UniBEaM,  $P(x, y)$  was obtained from the 2D Gaussian fit on the measured horizontal and vertical beam profiles, while for the  $\pi^2$ , the 2D beam profile is directly available from the captured image.

Figure 11 compares, for different primary beam intensities, the calculated proton flux versus the flux measured with the Faraday cup (obtained by dividing the Faraday cup current by the collimator aperture). The results for both beam profile monitors show similar performance, compatible with the 10% uncertainty on the calculated flux, as described in section 3.3.



**Figure 10.** Validation of the irradiation setup. The UniBEaM (1) was installed before the collimator (2), mimicking a typical irradiation setup. A Faraday cup (3) was installed at the DUT position to measure the beam current.

### 3.4.2 Validation using radiochromic films


In this experiment, a set of calibrated radiochromic films were irradiated in incremental time intervals, with the goal of comparing the TID extracted from the change in colouration of the film, with the expected TID based on the calculated proton fluence, obtained by integrating the flux calculated using eq. 3.2. FWT-60 radiochromic films from Far West Technology (FWT) [30] were used. They consist of hexa(hydroxyethyl) aminotriphenylacetonitrile (HHEVC) dyes, and are available in different thicknesses (10  $\mu\text{m}$  and 47  $\mu\text{m}$ ).

Since the thickness of the film is much smaller than the proton range in the material, the energy loss of the protons in the film can be neglected and the TID ( $\mathcal{D}_{\text{ion}}$ ) can be calculated from the integrated proton flux:

$$\mathcal{D}_{\text{ion}} = \frac{1}{\rho} \frac{dE}{dx_{\text{ion}}} \cdot \int_{t_0}^{t_1} \phi(t) dt \quad (3.3)$$

where  $\frac{dE}{dx_{\text{ion}}}$  is the electronic stopping power of the material for protons,  $\rho$  the material density,  $\phi(t)$  the instantaneous proton flux and  $[t_0, t_1]$  the irradiation interval. From SRIM, the stopping power of HHEVC for a 16.7 MeV proton beam is 30.87 MeV  $\cdot$  cm<sup>2</sup>g<sup>-1</sup>.

Figure 12 shows the optical absorbance of the films after irradiation in the BTL against the TID determined from Equations 3.2 and 3.3 (blue circles), compared with the calibration provided by the manufacturer (red squares). The bottom plot shows the ratio between the calculated dose and the one expected from the calibration at the same optical absorbance. To minimise the uncertainty on the optical absorbance several films were irradiated to each dose step in independent measurements. The




**Figure 11.** Proton flux obtained using Equation 3.2 for the UniBEaM (red squares) and the  $\pi^2$  (blue circles), as a function of the flux obtained from the beam current measured on the Faraday cup. To guide the eye, the dashed line represents the identity function. For both beam profilers, the calculated proton flux is compatible within 10% with the Faraday cup measurement, as shown by the ratio in the bottom plot.

uncertainty on the measured optical absorbance takes into account an uncertainty of  $5 \mu\text{m}$  on the film thickness, as indicated by FWT. A 10% uncertainty associated to the proton flux determination, as discussed for the previous measurement, was considered for the calculation of the TID. In addition, the uncertainty on the beam energy ( $16.7 \pm 0.5 \text{ MeV}$ ) translates into a 5% uncertainty on the stopping power value. An agreement within 15% is observed between the measurements and the calibration, thus validating the proton flux calculation method described in the previous section.

### 3.5 On site characterisation of the irradiated samples

The Physics Laboratory is located within the Cyclotron radiation-controlled area. It is a space fully dedicated to the research activities conducted in the BTL bunker. From the Physics Laboratory the users can operate their instruments in the BTL bunker via a patch panel featuring BNC, SHV, Ethernet, and different flavours of multi-pin and fibre optic connectors. NIM crates and electronics modules for signal acquisition, as well as common table-top electronics are also available in the laboratory.




**Figure 12.** Comparison between the TID measured using the method described in this document (blue circles) and the one determined from the change in colour of the radiochromic films, according to the calibration provided by FWT (red squares) [30]. The two measurements are compatible within 15% as shown by the ratio in the bottom plot.

The Physics Laboratory also constitutes a space to perform post-irradiation studies, often suppressing the need to transport radioactive material outside the facility. The laboratory equipment can be used for the characterisation of irradiated samples, but it is also possible for users to move their own characterisation setup to the facility. The laboratory is equipped with a HPGe gamma-spectrometer and an alpha-spectrometer, as well as a freezer for storage of irradiated samples at low temperature, in the case that undesired annealing effects need to be avoided.

#### 4 Examples of irradiation campaigns

The Bern Medical Cyclotron is involved in the qualification of new sensor technologies, as well as other materials, in view of the detector upgrades for the High-Luminosity LHC. As an example, the radiation hardness of high-voltage CMOS pixel sensors has been tested to a fluence of  $1.9 \times 10^{15} \text{ n}_{\text{eq}}/\text{cm}^2$  [31, 32]. Currently, an extensive irradiation campaign is ongoing, aiming to validate the radiation tolerance of the data transmission chain [33] for the read-out of the Inner



**Figure 13.** Left: setup used to irradiate a 6-metre long twinax cable for the ATLAS ITk pixel readout chain. Right: Insertion Loss measured with a Vector Network Analyser at different dose levels.

Tracker (ITk) pixel detector of the ATLAS experiment [34]. To this end, diverse components such as cable shieldings, connectors and electrical cables have been irradiated. Figure 13 (left) shows the setup used to irradiate the cables connecting the detector front-end modules to the opto-electronic converters [35]. To achieve a uniform dose along the cable length, the cable was wrapped on a spool mounted on a motor, so that the spool could rotate during the irradiation. The spool was enclosed in a metallic container coupled directly to the BTL after the extraction window, in order to limit the amount of radioactivity induced in air. The right-hand part of the figure corresponds to the change in transfer function ( $S_{21}$ ) of the cable due to the irradiation, measured using a Vector Network Analyser. The facility has also been used to test the radiation hardness of components for space missions such as the Neutral gas and Ion Mass spectrometer (NIM) onboard ESA’s JUpiter ICy moon Explorer (JUICE) [36, 37], and to study radiation effects on glass windows for optical readout of Gas Electron Multiplier (GEM) based detectors, targeting hadrontherapy applications [38].

## 5 Conclusions

The Bern Medical Cyclotron, an accelerator primarily used for production of medical radioisotopes, is in operation as an irradiation facility thanks to a Beam Transfer Line (BTL) that can transport the 18-MeV proton beam to an adjacent bunker fully dedicated to research activities. Among other projects, the beam line is used for radiation hardness studies of electronics and materials for scientific applications. A dedicated setup for monitoring the fluence during the irradiation was developed, consisting of two independent instruments: a beam profiler, to measure the transversal beam profile, and a collimator, to measure the beam current. This method was validated in two dedicated measurements. In the first, the proton flux calculated from the beam profile and collimator current was compared with a direct measurement of the beam current using a Faraday cup. An agreement within 10% between both measurements was obtained for a proton flux ranging from  $5 \times 10^9 \text{ cm}^{-2}\text{s}^{-1}$  to  $4 \times 10^{11} \text{ cm}^{-2}\text{s}^{-1}$ . In the second, a set of radiochromic films were irradiated to different TID levels.

The dose calculated from the beam current and profile and the dose determined by the film colour change were found to be compatible within 15%. The facility features also a Physics Laboratory equipped with a wide range of electronics equipment, as well as gamma and alpha spectrometers, thus allowing in depth post-irradiation studies to be performed directly on site. The Bern Medical Cyclotron has hosted different irradiation campaigns for high-energy physics experiments, such as ATLAS, CMS and LHCb, and as well as for astrophysics and medical physics studies.

## Acknowledgments

We acknowledge contributions from the LHEP engineering and technical staff who helped us with the mechanical and electronics challenges occurred during the design, the development and installation of the irradiation facility. We thank the SWAN Isotopen AG maintenance team for the support and the collaboration. This work was partially funded by the Swiss National Science Foundation (SNSF) (grants 200020\_204241, 200020\_188442, 20FL20\_201478, 20FL20\_173601, CR23I2\_156852, 200021\_175749, CRSII5\_180352, CR23I2\_156852).

## References

- [1] G. Furano, R. Jansen and A. Menicucci, *Review of radiation hard electronics activities at European Space Agency*, [2013 JINST 8 C02007](#).
- [2] C. Poivey, *Radiation Hardness Assurance for Space Systems*, presented at the *IEEE NSREC Short Course*, 2002.
- [3] K. LaBel, A. Johnston, J. Barth, R. Reed and C. Barnes, *Emerging radiation hardness assurance (RHA) issues: a NASA approach for space flight programs*, *IEEE Trans. Nucl. Sci.* **45** (1998) 2727.
- [4] O. S. Brüning, P. Collier, P. Lebrun, S. Myers, R. Ostojic, J. Poole et al., *LHC Design Report*, CERN Yellow Reports: Monographs, CERN, Geneva, 2004, [10.5170/CERN-2004-003-V-1](#).
- [5] O. Aberle, I. Béjar Alonso, O. Brüning, P. Fessia, L. Rossi, L. Taviani et al., *High-Luminosity Large Hadron Collider (HL-LHC): Technical design report*, CERN Yellow Reports: Monographs. CERN, Geneva, 2020, [10.23731/CYRM-2020-0010](#).
- [6] R. García Alía, M. Brugger, F. Cerutti, S. Danzeca, A. Ferrari, S. Gilardoni et al., *LHC and HL-LHC: Present and Future Radiation Environment in the High-Luminosity Collision Points and RHA Implications*, *IEEE Trans. Nucl. Sci.* **65** (2018) 448.
- [7] M. Moll, *Displacement damage in silicon detectors for high energy physics*, *IEEE Trans. Nucl. Sci.* **65** (2018) 1561.
- [8] RD53 collaboration, *RD53A: A large-scale prototype chip for the phase II upgrade in the serially powered HL-LHC pixel detectors*, *Nucl. Instrum. Meth. A* **958** (2020) 162091.
- [9] M. Esposito, T. Anaxagoras, O. Diaz, K. Wells and N. M. Allinson, *Radiation hardness of a large area CMOS active pixel sensor for bio-medical applications*, in proceedings of *IEEE Nuclear Science Symposium and Medical Imaging Conference Record*, Anaheim, CA, U.S.A., 27 October–3 November 2012, pp. 1300–1304.
- [10] I.A. Zahradnik, M.T. Pomorski, L. De Marzi, D. Tromson, P. Barberet, N. Skukan et al., *scCVD Diamond Membrane based Microdosimeter for Hadron Therapy*, *phys. status solidi (a)* **215** (2018) 1800383.

- [11] K. Vukolov, A. Borisov, N. Deryabina and I. Orlovskiy, *Development of ITER diagnostics: Neutronic analysis and radiation hardness*, *Fusion Eng. Des.* **96-97** (2015) 177.
- [12] J.M. Rafí, G. Pellegrini, P. Godignon, S.O. Ugobono, G. Rius, I. Tsunoda et al., *Electron, Neutron, and Proton Irradiation Effects on SiC Radiation Detectors*, *IEEE Trans. Nucl. Sci.* **67** (2020) 2481.
- [13] J.F. Ziegler, M.D. Ziegler and J.P. Biersack, *SRIM - The stopping and range of ions in matter* (2010), *Nucl. Instrum. Meth. B* **268** (2010) 1818.
- [14] *Bern medical cyclotron irradiation facility*, [https://www.lhep.unibe.ch/research/medical\\_applications/index\\_eng.html](https://www.lhep.unibe.ch/research/medical_applications/index_eng.html).
- [15] S. Braccini, *The new Bern PET cyclotron, its research beam line, and the development of an innovative beam monitor detector*, *AIP Conf. Proc.* **1525** (2013) 144.
- [16] P. Scampoli, K. von Bremen, S. Braccini and A. Ereditato, *The New Bern Cyclotron Laboratory for Radioisotope Production and Research*, *Conf. Proc. C* **110904** (2011) 3619.
- [17] N.P. van der Meulen, R. Hasler, Z. Talip, P.V. Grundler, C. Favaretto, C.A. Umbricht et al., *Developments toward the Implementation of  $^{44}\text{Sc}$  Production at a Medical Cyclotron*, *Molecules* **25** (2020) 4706.
- [18] S. Braccini, C. Belver-Aguilar, T. Carzaniga, G. Dellepiane, P. Haeffner and P. Scampoli, *Novel Irradiation Methods for Theranostic Radioisotope Production With Solid Targets at the Bern Medical Cyclotron*, in *Proceedings of Cyclotrons'19*, Cape Town, South Africa, 23–27 September 2019, pp. 127–131.
- [19] C. Belver-Aguilar, S. Braccini, T. Carzaniga, A. Gsponer, P. Häffner, G. Molinari et al., *Development of Novel Non-Destructive 2D and 3D Beam Monitoring Detectors at the Bern Medical Cyclotron*, in *Proceedings of the 9<sup>th</sup> International Beam Instrumentation Conference*, Santos, Brazil, 14–18 September 2020, pp. 78–81.
- [20] C. Belver-Aguilar, S. Braccini, T. S. Carzaniga, A. Gsponer, P. D. Häffner, P. Scampoli et al., *A Novel Three-Dimensional Non-Destructive Beam-Monitoring Detector*, *Appl. Sci.* **10** (2020) 8217.
- [21] S. Braccini, A. Ereditato, K. Nesteruk, P. Scampoli and K. Zihlmann, *Study of the radioactivity induced in air by a 15-MeV proton beam*, *Radiat. Protect. Dosim.* **163** (2015) 269.
- [22] K.P. Nesteruk, L. Ramseyer, T.S. Carzaniga and S. Braccini, *Measurement of the Beam Energy Distribution of a Medical Cyclotron with a Multi-Leaf Faraday Cup*, *Instruments* **3** (2019) 4.
- [23] K.P. Nesteruk, M. Auger, S. Braccini, T.S. Carzaniga, A. Ereditato and P. Scampoli, *A system for online beam emittance measurements and proton beam characterization*, *2018 JINST* **13** P01011 [[arXiv:1705.07486](https://arxiv.org/abs/1705.07486)].
- [24] P. Häffner, C.B. Aguilar, S. Braccini, P. Scampoli and P.A. Thonet, *Study of the Extracted Beam Energy as a Function of Operational Parameters of a Medical Cyclotron*, *Instruments* **3** (2019) 63.
- [25] M. Auger, S. Braccini, A. Ereditato, K.P. Nesteruk and P. Scampoli, *Low current performance of the Bern medical cyclotron down to the pA range*, *Meas. Sci. Technol.* **26** (2015) 094006.
- [26] M. Auger, S. Braccini, T.S. Carzaniga, A. Ereditato, K.P. Nesteruk and P. Scampoli, *A detector based on silica fibers for ion beam monitoring in a wide current range*, *2016 JINST* **11** P03027.
- [27] *D-PACE*, <https://www.d-pace.com/>.
- [28] *NIST database*, <https://dx.doi.org/10.18434/T4NC7P>.

- [29] ATLAS collaboration, *Irradiation induced effects in the FE-I4 front-end chip of the ATLAS IBL detector*, in *2016 IEEE Nuclear Science Symposium and Medical Imaging Conference*, Strasbourg, France, 29 October–6 November 2016, pp. 1–4 [[arXiv:1611.00803](#)].
- [30] *Far West Technologies*, <http://www.fwt.com/racm/fwt60ds.htm>.
- [31] M. Benoit et al., *Testbeam results of irradiated ams H18 HV-CMOS pixel sensor prototypes*, 2018 *JINST* **13** P02011 [[arXiv:1611.02669](#)].
- [32] J. Anders et al., *Charge collection characterisation with the Transient Current Technique of the ams H35DEMO CMOS detector after proton irradiation*, 2018 *JINST* **13** P10004 [[arXiv:1807.09553](#)].
- [33] L. Franconi, *The Opto-electrical conversion system for the data transmission chain of the ATLAS ITk Pixel detector upgrade for the HL-LHC*, in *Proceedings of International Conference on Technology and Instrumentation in Particle Physics 2021*, 2021, in press [<https://cds.cern.ch/record/2773360>].
- [34] ATLAS collaboration, *The ATLAS Experiment at the CERN Large Hadron Collider*, 2008 *JINST* **3** S08003.
- [35] L. Halser, *Irradiation studies at the Bern cyclotron for the ATLAS ITk upgrade*, in *Proceedings of International Conference on Technology and Instrumentation in Particle Physics 2021*, 2021, in press [<https://cds.cern.ch/record/2773815>].
- [36] D. Lasi, S. Meyer, D. Piazza, M. Lüthi, A. Nentwig, M. Gruber et al., *Decisions and Trade-Offs in the Design of a Mass Spectrometer for Jupiter’s Icy Moons*, in *Proceedings of IEEE Aerospace Conference*, Big Sky, MT, U.S.A., 7–14 March 2020, pp. 1–20.
- [37] D. Lasi, M. Tulej, M.B. Neuland, P. Wurz, T.S. Carzaniga, K.P. Nesteruk et al., *Testing the Radiation Hardness of Thick-Film Resistors for a Time-Of-Flight Mass Spectrometer at Jupiter with 18 MeV Protons*, in *2017 IEEE Radiation Effects Data Workshop (REDW)*, New Orleans, LA, U.S.A., 17–21 July 2017, pp. 1–9.
- [38] A.M. Oliveira, S. Braccini, P. Casolaro, N. Heracleous, J. Leidner, I. Mateu et al., *Radiation-induced effects in glass windows for optical readout GEM-based detectors*, 2021 *JINST* **16** T07009 [[arXiv:2106.04645](#)].