

Geometric Ultrasound Localization Microscopy

Christopher Hahne^(✉) and Raphael Sznitman

ARTORG Center, University of Bern, Switzerland
christopher.hahne@unibe.ch

Abstract. Contrast-Enhanced Ultra-Sound (CEUS) has become a viable method for non-invasive, dynamic visualization in medical diagnostics, yet Ultrasound Localization Microscopy (ULM) has enabled a revolutionary breakthrough by offering ten times higher resolution. To date, Delay-And-Sum (DAS) beamformers are used to render ULM frames, ultimately determining the image resolution capability. To take full advantage of ULM, this study questions whether beamforming is the most effective processing step for ULM, suggesting an alternative approach that relies solely on Time-Difference-of-Arrival (TDoA) information. To this end, a novel geometric framework for microbubble localization via ellipse intersections is proposed to overcome existing beamforming limitations. We present a benchmark comparison based on a public dataset for which our geometric ULM outperforms existing baseline methods in terms of accuracy and robustness while only utilizing a portion of the available transducer data.

Keywords: Ultrasound · Microbubble · Localization · Microscopy · Geometry · Parallax · Triangulation · Trilateration · Multilateration · Time-of-Arrival

1 Introduction

Ultrasound Localization Microscopy (ULM) has revolutionized medical imaging by enabling sub-wavelength resolution from images acquired by piezo-electric transducers and computational beamforming. However, the necessity of beamforming for ULM remains questionable. Our work challenges the conventional assumption that beamforming is the ideal processing step for ULM and presents an alternative approach based on geometric reconstruction from Time-of-Arrival (ToA) information.

The discovery of ULM has recently surpassed the diffraction-limited spatial resolution and enabled highly detailed visualization of the vascularity [8]. ULM borrows concepts from super-resolution fluorescence microscopy techniques to precisely locate individual particles with sub-pixel accuracy over multiple frames. By the accumulation of all localizations over time, ULM can produce a super-resolved image, providing researchers and clinicians with highly detailed representation of the vascular structure.

While Contrast-Enhanced Ultra-Sound (CEUS) is used in the identification of musculoskeletal soft tissue tumours [5], the far higher resolution capability offered by ULM has great potential for clinical translation to improve the reliability of cancer diagnosis (*i.e.*, enable differentiation of tumour types in kidney cancer [7] or detect breast cancer tissue [1]). Moreover, ULM has shown promise in imaging neurovascular activity after visual stimulation (functional ULM) [14]. The pioneering study by Errico *et*




Fig. 1: Comparison of ULM processing pipelines: Classical ULM (top) employs computational beamforming from N channels and image filters to localize microbubbles. Our geometric ULM (bottom) consists of a cross-channel phase-consistent Time-of-Arrival detection (left) to form ellipses that intersect at a microbubble position (middle). As a refinement step, ellipse intersections are fused via clustering (right).

al. [8] initially demonstrated the potential of ULM by successfully localizing contrast agent particles (microbubbles) using a 2D point-spread-function model. In general, the accuracy in MicroBubble (MB) localization is the key to achieving sub-wavelength resolution [4], for which classical imaging methods [17,11], as well as deep neural networks [16,1], have recently been reported.

However, the conventional approach for ULM involves using computational beamformers, which may not be ideal for MB localization. For example, a recent study has shown that ultrasound image segmentation can be learned from radio-frequency data and thus without beamforming [13]. Beamforming techniques have been developed to render irregular topologies, whereas MBs exhibit a uniform geometric structure, for which ULM only requires information about its spatial position. Although the impact of adaptive beamforming has been studied for ULM to investigate its potential to refine MB localization [3], optimization of the Point-Spread Function (PSF) poses high demands on the transducer array, data storage, and algorithm complexity.

To this end, we propose an alternative approach for ULM, outlined in Fig. 1, that entirely relies on Time-Difference-of-Arrival (TDoA) information, omitting beamforming from the processing pipeline for the first time. We demonstrate a novel geometry framework for MB localization through ellipse intersections to overcome limitations inherent to beamforming. This approach provides a finer distinction between overlapping and clustered spots, improving localization precision, reliability, and computation efficiency. In conclusion, we challenge the conventional wisdom that beamforming is necessary for ULM and propose a novel approach that entirely relies on TDoA information for MB localization. Our proposed approach demonstrates promising results and indicates a considerable trade-off between precision, computation, and memory.

2 Method

Geometric modeling is a useful approach for locating landmarks in space. One common method involves using a Time-of-Flight (ToF) round-trip setup that includes a transmitter and multiple receivers [10]. This setup is analogous to the parallax concept in visual imaging, where a triangle is formed between the target, emitter, and receivers, as illustrated in Figure 2. The target's location can be accurately estimated using trilateration by analyzing the time delay between the transmitted and received signals. However, the triangle's side lengths are unknown in the single receiver case, and all possible travel path candidates form triangles with equal circumferences fixed at the axis connecting the receiver and the source. These candidates reside on an elliptical shape. By adding a second receiver, its respective ellipse intersects with the first one resolving the target's 2-D position. Thus, the localization accuracy depends on the ellipse model, which is parameterized by the known transducer positions and the time delays we seek to estimate. This section describes a precise echo feature extraction, which is essential for building the subsequent ellipse intersection model. Finally, we demonstrate our localization refinement through clustering.

2.1 Feature Extraction

Feature extraction of acoustic signals has been thoroughly researched [18,9]. To leverage the geometric ULM localization, we wish to extract Time-of-Arrival (ToA) information (instead of beamforming) at sub-wavelength precision. Despite the popularity of deep neural networks, which have been studied for ToA detection [18], we employ an energy-based model [9] for echo feature extraction to demonstrate the feasibility of our geometric ULM at the initial stage. Ultimately, future studies can combine our proposed localization with a supervised network. Here, echoes $f(\mathbf{m}_k; t)$ are modeled as Multimodal Exponentially-Modified Gaussian Oscillators (MEMGO) [9],

$$f(\mathbf{m}_k; t) = \alpha_k \exp\left(-\frac{(t - \mu_k)^2}{2\sigma_k^2}\right) \left(1 + \operatorname{erf}\left(\eta_k \frac{t - \mu_k}{\sigma_k \sqrt{2}}\right)\right) \cos(\omega_k (t - \mu_k) + \phi_k), \quad (1)$$

where $t \in \mathbb{R}^T$ denotes the time domain with a total number of T samples and $\mathbf{m}_k = [\alpha_k, \mu_k, \sigma_k, \eta_k, \omega_k, \phi_k]^\top \in \mathbb{R}^6$ contains the amplitude α_k , mean μ_k , spread σ_k , skew η_k , angular frequency ω_k and phase ϕ_k for each echo k . Note that $\operatorname{erf}(\cdot)$ is the error function. To estimate these parameters iteratively, the cost function is given by,

$$\mathcal{L}_E(\hat{\mathbf{m}}_n) = \left\| y_n(t) - \sum_{k=1}^K f(\mathbf{m}_k; t) \right\|_2^2, \quad (2)$$

where $y_n(t)$ is the measured signal from waveform channel $n \in \{1, 2, \dots, N\}$ and the sum over k accumulates all echo components $\hat{\mathbf{m}}_n = [\mathbf{m}_1^\top, \mathbf{m}_2^\top, \dots, \mathbf{m}_K^\top]^\top$. We get

the best echo feature set $\hat{\mathbf{m}}_n^*$ over all iterations j via,

$$\hat{\mathbf{m}}_n^* = \arg \min_{\hat{\mathbf{m}}_n^{(j)}} \left\{ \mathcal{L}_E \left(\hat{\mathbf{m}}_n^{(j)} \right) \right\}, \quad (3)$$

for which we use the Levenberg-Marquardt solver. Model-based optimization requires initial estimates to be nearby the solution space. For this, we detect initial ToAs via gradient-based analysis of the Hilbert-transformed signal to set $\hat{\mathbf{m}}_n^{(1)}$ as in [9].

Before geometric localization, one must ensure that detected echo components correspond to the same MB. In this work, echo matching is accomplished in a heuristic brute-force fashion. Given an echo component $\mathbf{m}_{n,k}^*$ from a reference channel index n , a matching echo component from an adjacent channel index $n \pm g$ with gap $g \in \mathbb{N}$ is found by $k + h$ in the neighborhood of $h \in \{-1, 0, 1\}$. A corresponding phase-precise ToA $t_{n,k}^*$ is obtained by $t_{n \pm g, k}^* = \mu_{n \pm g, k+h}^* + \phi_{n,k}^* - \Delta$, which takes $\mu_{n,k}^*$ and $\phi_{n,k}^*$ from $\hat{\mathbf{m}}_n^*$ for phase-precise alignment across transducer channels after upsampling. Here, Δ is a fixed offset to accurately capture the onset of the MB locations [2]. We validate echo correspondence through a re-projection error in adjacent channels and reject those with weak alignment.

2.2 Ellipse Intersection

While ellipse intersections can be approximated iteratively, we employ Eberly's closed-form solution [6] owing to its fast computation property. Although one might expect that the intersection of arbitrarily placed ellipses is straightforward, it involves advanced mathematical modelling due to the degrees of freedom in the ellipse positioning. An ellipse is drawn by radii (r_a, r_b) of the major and minor axes with,

$$r_a = \frac{t_{n,k}^*}{2}, \quad \text{and} \quad r_b = \frac{1}{2} \sqrt{\left(t_{n,k}^*\right)^2 - \|\hat{\mathbf{u}}_s - \mathbf{u}_n\|_2^2}, \quad (4)$$

where the virtual transmitter $\hat{\mathbf{u}}_s \in \mathbb{R}^2$ and each receiver $\mathbf{u}_n \in \mathbb{R}^2$ with channel index n represent the focal points of an ellipse, respectively. For the intersection, we begin with the ellipse standard equation. Let any point $\mathbf{s} \in \mathbb{R}^2$ located on an ellipse and displaced by its center $\mathbf{c}_n \in \mathbb{R}^2$ such that,

$$(\mathbf{s} - \mathbf{c}_n)^\top \left(\frac{\|\mathbf{v}_n\|_2^2}{r_a^2 |\mathbf{v}_n|_2^2} + \frac{\|\mathbf{v}_n^\perp\|_2^2}{r_b^2 |\mathbf{v}_n^\perp|_2^2} \right) (\mathbf{s} - \mathbf{c}_n) = (\mathbf{s} - \mathbf{c}_n)^\top \mathbf{M} (\mathbf{s} - \mathbf{c}_n) = 1, \quad (5)$$




Fig. 2: Transducer geometry used for the ellipse intersection and localization of a MB position \mathbf{s}^* from virtual source $\hat{\mathbf{u}}_s$ and receiver positions \mathbf{u}_n , which span ellipses rotated by \mathbf{v}_n around their centers \mathbf{c}_n .

where \mathbf{M} contains the ellipse equation with \mathbf{v}_n and \mathbf{v}_n^\perp as a pair of orthogonal ellipse direction vectors, corresponding to their radial extents (r_0, r_1) as well as the squared norm $\|\cdot\|_2^2$ and vector norm $|\cdot|$. For subsequent root-finding, it is the goal to convert the standard Eq. (5) to a quadratic polynomial with coefficients b_j given by, $B(x, y) = b_0 + b_1x + b_2y + b_3x^2 + b_4xy = 0$, which, when written in vector-matrix form reads,

$$0 = [x \ y] \begin{bmatrix} b_3 & b_4/2 \\ b_4/2 & b_5 \end{bmatrix} \begin{bmatrix} x \\ y \end{bmatrix} + [b_1 \ b_2] \begin{bmatrix} x \\ y \end{bmatrix} + b_0 = \mathbf{s}^\top \mathbf{B} \mathbf{s} + \mathbf{b}^\top \mathbf{s} + b_0, \quad (6)$$

where \mathbf{B} and \mathbf{b} carry high-order polynomial coefficients b_j found via matrix factorization [6]. An elaborated version of this is found in the supplementary material.

Let two intersecting ellipses be given as quadratic equations $A(x, y)$ and $B(x, y)$ with coefficients a_j and b_j , respectively. Their intersection is found via polynomial root-finding of the equation,

$$D(x, y) = d_0 + d_1x + d_2y + d_3x^2 + d_4xy = 0, \quad (7)$$

where $\forall j, d_j = a_j - b_j$. When defining $y = w - (a_2 + a_4x)/2$ to substitute y , we get $A(x, w) = w^2 + (a_0 + a_1x + a_3x^2) - (a_2 + a_4x)^2/4 = 0$ which after rearranging is plugged into (7) to yield an intersection point $\mathbf{s}_i^* = [x_i, w_i]^\top$. We refer the interested reader to the insightful descriptions in [6] for further implementation details.

2.3 Clustering

Micro bubble reflections are dispersed across multiple waveform channels yielding groups of location candidates for the same target bubble. Localization deviations result from ToA variations, which can occur due to atmospheric conditions, receiver clock errors, and system noise. Due to the random distribution of corresponding ToA errors [8], we regard these candidates as clusters. Thus, we aim to find a centroid \mathbf{p}^* of each cluster using multiple bi-variate probability density functions of varying sample sizes by,

$$m(\mathbf{p}^{(j)}) = \frac{\sum_{\mathbf{s}_i^* \in \Omega^{(j)}} \exp(-\|\mathbf{s}_i^* - \mathbf{p}^{(j)}\|_2^2) \mathbf{s}_i^*}{\sum_{\mathbf{s}_i^* \in \Omega^{(j)}} \exp(-\|\mathbf{s}_i^* - \mathbf{p}^{(j)}\|_2^2)} \quad (8)$$

Here, the bandwidth of the kernel is set to $\lambda/4$. The Mean Shift algorithm updates the estimate $\mathbf{p}^{(j)}$ by setting it to the weighted mean density on each iteration j until convergence. In this way, we obtain the position of the target bubble.

3 Experiments

Dataset: We demonstrate the feasibility of our geometric ULM and present benchmark comparison outcomes based on the PALA dataset [11]. This dataset is chosen as it is publicly available, allowing easy access and reproducibility of our results. To date, it is the only public ULM dataset featuring Radio Frequency (RF) data as required by our method. Its third-party simulation data makes it possible to perform a numerical quantification and direct comparison of different baseline benchmarks for the first time, which is necessary to validate the effectiveness of our proposed approach.

Metrics: For MB localization assessment, the minimum Root Mean Squared Error (RMSE) between the estimated \mathbf{p}^* and the nearest ground truth position is computed. To align with the PALA study [11], only RMSEs less than $\lambda/4$ are considered true positives and contribute to the total RMSE of all frames. In cases where the RMSE distance is greater than $\lambda/4$, the estimated \mathbf{p}^* is a false positive. Consequently, ground truth locations without an estimate within the $\lambda/4$ neighbourhood are false negatives. We use the Jaccard Index to measure the MB detection capability, which considers both true positives and false negatives and provides a robust measure of each algorithm’s performance. The Structural Similarity Index Measure (SSIM) is used for image assessment.

For a realistic analysis, we employ the noise model used in [11], which is given by,

$$n(t) \sim \mathcal{N}(0, \sigma_p^2) \times \max(y_n(t)) \times 10^{(L_A+L_C)/20} \pm \max(y_n(t)) \times 10^{L_C/20}, \quad (9)$$

where $\sigma_p = \sqrt{B \times 10^{P/10}}$ and $\mathcal{N}(0, \sigma_p^2)$ are normal distributions with mean 0 and variance σ_p^2 . Here, L_C and L_A are noise levels in dB, and $n(t)$ is the array of length T containing the random values drawn from this distribution. The additive noise model is then used to simulate a waveform channel $y'_n(t) = y_n(t) + n(t) \otimes g(t, \sigma_f)$ suffering from noise, where \otimes represents the convolution operator, and $g(t, \sigma_f)$ is the one-dimensional Gaussian kernel with standard deviation $\sigma_f = 1.5$. To mimic the noise reduction achieved through the use of sub-aperture beamforming with 16 transducer channels [11], we multiplied the RF data noise by a factor of 4 for an equitable comparison.

Baselines: We compare our approach against state-of-the-art methods that utilize beamforming together with classical image filterings [8], Spline interpolation [17], Radial Symmetry (RS) [11] and a deep-learning-based U-Net [16] for MB localization. To only focus on the localization performance of each algorithm, we conduct the experimental analysis without temporal tracking. We obtain the results for classical image processing approaches directly from the open-source code provided by the authors of the PALA dataset [11]. As there is no publicly available implementation of [16] to date, we model and train the U-Net [15] according to the paper description, including loss design, layer architecture, and the incorporation of dropout. Since the U-Net-based localization is a supervised learning approach, we split the PALA dataset into sequences 1-15 for testing and 16-20 for training and validation, with a split ratio of 0.9, providing a sufficient number of 4500 training frames.

Results: Table 1 provides the benchmark comparison results with state-of-the-art methods. Our proposed geometric inference indicates the best localization performance represented by an average RMSE of around one-tenth of a wavelength. Also, the Jaccard Index reflects an outperforming balance of true positive and false negative MB detections by our approach. These results support the hypothesis that our proposed geometric localization inference is a considerable alternative to existing beamforming-based methods. Upon closer examination of the channels column in Table 1, it becomes apparent that our geometric ULM achieves reasonable localization performance with

Table 1: Summary of localization results using 15k frames of the PALA dataset [11]. The RMSE is reported as mean \pm std, best scores are bold and units are given in brackets.

Method	Channels [#]	RMSE [$\lambda/10$]	Jaccard [%]	Time [s]	SSIM [%]
Weighted Avg. [11]	128	1.287 \pm 0.162	44.253	0.080	69.49
Lanczos [11]	128	1.524 \pm 0.175	38.688	0.382	75.87
RS [11]	128	1.179 \pm 0.172	50.330	0.099	72.17
Spline [17]	128	1.504 \pm 0.174	39.370	0.277	75.72
2-D Gauss Fit [17]	128	1.240 \pm 0.162	51.342	3.782	73.93
U-Net [16]	128	1.561 \pm 0.154	52.078	0.004	90.07
	8	1.116 \pm 0.206	38.113	0.268	79.74
	16	1.077 \pm 0.136	66.414	0.485	87.10
G-ULM	32	1.042 \pm 0.125	72.956	0.945	92.18
(proposed)	64	1.036 \pm 0.124	73.175	1.317	93.70
	128	0.967 \pm 0.109	78.618	3.747	92.02

only a fraction of the 128 channels available in the transducer probe. Using more than 32 channels improves the Jaccard Index but at the expense of computational resources. This finding confirms the assumption that transducers are redundant for MB tracking. The slight discrepancy in SSIM scores between our 128-channel results and the 64-channel example may be attributed to the higher number of false positives in the former, which decreases the overall SSIM value.

We provide rendered ULM image regions for visual inspection in Fig. 3 with full frames in the supplementary material. To enhance visibility, all images are processed with sRGB and additional gamma correction using an exponent of 0.9. The presence of noisy points in Figs. 3b to 3d is attributed to the excessive false positive localizations, resulting in poorer SSIM scores. Overall, these visual observations align with the numerical results presented in Table 1. An NVIDIA RTX2080 GPU was used for all computations and time measurements. To improve performance, signal processing chains are often pipelined, allowing for the simultaneous computation of subsequent processes. Table 1 lists the most time-consuming process for each method, which acts as the bottleneck. For our approach, the MEMGO feature extraction is the computationally most expensive process, followed by clustering. However, our method contributes to an overall efficient computation and acquisition time, as it skips beamforming and coherent compounding [12] with the latter reducing the capture interval by two-thirds.

Table 2 presents the results for the best-of-3 algorithms at various noise levels L_C . As the amount of noise from (9) increases, there is a decline in the Jaccard Index, which suggests that each method is more susceptible to false detections from noise clutter. Although our method is exposed to higher noise in the RF domain, it is seen that L_C has a comparable impact on our method. However, it is important to note that the U-Net yields the most steady and consistent results for different noise levels.




Fig. 3: Rendered ULM regions from Table 1 in (a) to (d) and a rat brain result in (e) without temporal tracking. Numbers in curly brackets indicate the transducer number.

Table 2: Performance under noise variations from 128 (others) vs 16 (ours) transducers.

Noise	RMSE [$\lambda/10$]			Jaccard Index [%]			
	L_C [dB]	RS [11]	U-Net [16]	Ours	RS [11]	U-Net [16]	Ours
-30		1.245 ± 0.171	1.564 ± 0.151	1.076 ± 0.136	54.036	51.032	65.811
-20		1.496 ± 0.223	1.459 ± 0.165	1.262 ± 0.249	27.037	45.647	27.962
-10		1.634 ± 0.542	1.517 ± 0.238	1.459 ± 0.564	2.510	18.162	3.045

4 Summary

This study explored whether a geometric reconstruction may serve as an alternative to beamforming in ULM. We employed an energy-based model for feature extraction in conjunction with ellipse intersections and clustering to pinpoint contrast agent positions from RF data available in the PALA dataset. We carried out a benchmark comparison with state-of-the-art methods, demonstrating that our geometric model provides

enhanced resolution and detection reliability with fewer transducers. This capability will be a stepping stone for 3-D ULM reconstruction where matrix transducer probes typically consist of 32 transducers per row only. It is essential to conduct follow-up studies to evaluate the high potential of our approach in an extensive manner before entering a pre-clinical phase. The promising results from this study motivate us to expand our research to more RF data scenarios. We believe our findings will inspire further research in this exciting and rapidly evolving field.

Acknowledgments: This research is supported by the Hasler Foundation under project number 22027.

References

1. Bar-Shira, O., Grubstein, A., Rapson, Y., Suhami, D., Atar, E., Peri-Hanania, K., Rosen, R., Eldar, Y.C.: Learned super resolution ultrasound for improved breast lesion characterization. In: Medical Image Computing and Computer Assisted Intervention–MICCAI 2021: 24th International Conference, Strasbourg, France, September 27–October 1, 2021, Proceedings, Part VII 24. pp. 109–118. Springer (2021)
2. Christensen-Jeffries, K., Harput, S., Brown, J., Wells, P.N.T., Aljabar, P., Dunsby, C., Tang, M.X., Eckersley, R.J.: Microbubble axial localization errors in ultrasound super-resolution imaging. *IEEE Transactions on Ultrasonics, Ferroelectrics, and Frequency Control* **64**(11), 1644–1654 (2017)
3. Corazza, A., Muleki-Seya, P., Aissani, A.W., Couture, O., Basarab, A., Nicolas, B.: Microbubble detection with adaptive beamforming for ultrasound localization microscopy. In: 2022 IEEE International Ultrasonics Symposium (IUS). pp. 1–4. IEEE (2022)
4. Couture, O., Hingot, V., Heiles, B., Muleki-Seya, P., Tanter, M.: Ultrasound localization microscopy and super-resolution: A state of the art. *IEEE Transactions on Ultrasonics, Ferroelectrics, and Frequency Control* **65**(8), 1304–1320 (2018)
5. De Marchi, A., Del Prever, E.B., Cavallo, F., Pozza, S., Linari, A., Lombardo, P., Comandone, A., Piana, R., Faletti, C.: Perfusion pattern and time of vascularisation with ceus increase accuracy in differentiating between benign and malignant tumours in 216 musculoskeletal soft tissue masses. *European Journal of Radiology* **84**(1), 142–150 (2015)
6. Eberly, D.: Intersection of ellipses. Tech. rep., Geometric Tools, Redmond WA 98052 (2020)
7. Elbanna, K.Y., Jang, H.J., Kim, T.K., Khalili, K., Guimarães, L.S., Atri, M.: The added value of contrast-enhanced ultrasound in evaluation of indeterminate small solid renal masses and risk stratification of cystic renal lesions. *European Radiology* **31**, 8468–8477 (2021)
8. Errico, C., Pierre, J., Pezet, S., Desailly, Y., Lenkei, Z., Couture, O., Tanter, M.: Ultrafast ultrasound localization microscopy for deep super-resolution vascular imaging. *Nature* **527**(7579), 499–502 (2015)
9. Hahne, C.: Multimodal exponentially modified gaussian oscillators. In: 2022 IEEE International Ultrasonics Symposium (IUS). pp. 1–4 (2022)
10. Hahne, C.: 3-dimensional sonic phase-invariant echo localization. In: 2023 IEEE International Conference on Robotics and Automation (ICRA). pp. 4121–4127 (2023)
11. Heiles, B., Chavignon, A., Hingot, V., Lopez, P., Teston, E., Couture, O.: Performance benchmarking of microbubble-localization algorithms for ultrasound localization microscopy. *Nature Biomedical Engineering* **6**(5), 605–616 (2022)
12. Montaldo, G., Tanter, M., Bercoff, J., Benech, N., Fink, M.: Coherent plane-wave compounding for very high frame rate ultrasonography and transient elastography. *IEEE transactions on ultrasonics, ferroelectrics, and frequency control* **56**(3), 489–506 (2009)

13. Nair, A.A., Tran, T.D., Reiter, A., Bell, M.A.L.: A deep learning based alternative to beam-forming ultrasound images. In: 2018 IEEE International conference on acoustics, speech and signal processing (ICASSP). pp. 3359–3363. IEEE (2018)
14. Renaudin, N., Demené, C., Dizeux, A., Ialy-Radio, N., Pezet, S., Tanter, M.: Functional ultrasound localization microscopy reveals brain-wide neurovascular activity on a microscopic scale. *Nature Methods* **19**(8), 1004–1012 (2022)
15. Ronneberger, O., Fischer, P., Brox, T.: U-net: Convolutional networks for biomedical image segmentation. In: Medical Image Computing and Computer-Assisted Intervention–MICCAI 2015: 18th International Conference, Munich, Germany, October 5-9, 2015, Proceedings, Part III 18. pp. 234–241. Springer (2015)
16. van Sloun, R.J., Solomon, O., Bruce, M., Khaing, Z.Z., Wijkstra, H., Eldar, Y.C., Mischi, M.: Super-resolution ultrasound localization microscopy through deep learning. *IEEE transactions on medical imaging* **40**(3), 829–839 (2020)
17. Song, P., Manduca, A., Trzasko, J., Daigle, R., Chen, S.: On the effects of spatial sampling quantization in super-resolution ultrasound microvessel imaging. *IEEE transactions on ultrasonics, ferroelectrics, and frequency control* **65**(12), 2264–2276 (2018)
18. Zonzini, F., Bogomolov, D., Dhamija, T., Testoni, N., De Marchi, L., Marzani, A.: Deep learning approaches for robust time of arrival estimation in acoustic emission monitoring. *Sensors* **22**(3) (2022)